

District Level water Testing Laboratory

P.H.Division, Aurangabad

Sample Collected by:- Self

Sample Submitted in Lab on Date:- 14.05.2026

Date of performance:- 14.05.2026 to 16.05.2026



District Name :- Aurangabad

Month S.No	Block	Panchayat	Village	Ward No	Location of Source	Chemical Parameters											
						pH	Turbidity	Electrical Conductivity	Total Dissolve Solid	Total Hardness	Calcium	Magnesium	Chloride	Total Alkalinity	Sulphate	Fluoride	Total Coliform
31	Aurangabad	Ora	Yari		Vivekanand vision Ideal PublicSchool Bignanika nagar Yari	7.16	0.86	892	580	225	84.8	26.91	47.55	243	11	0.24	-ve
					Acceptable Limit (IS 10500:2012)	6.50	1NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	200 mg/l	1.00 mg/l	<1.1
					Maximum Permissible Limit in absence of alteranate source	8.50	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	400 mg/l	1.50 mg/l	NR

इस विद्यालय का जल जाँच प्रत्येक छह माह पर कराना सुनिश्चित करें।

Shailendra
16.05.26

Chemist

P.H.Division, Aurangabad

Chemist

P.H.Division

Aurangabad

Assistant Engineer

P.H.Division, Aurangabad

16/05/2026

Chem

Assistant Engineer

P.H. Division, Aurangabad

Principal

Vivekanand Vision Ideal Public School

Bignaniknagar Yari

DCC-Aurangapura Road

Aurangabad (Bihar)

Executive Engineer

P.H.Division, Aurangabad

Quality Manager

Chem

Executive Engineer

P.H.Division, Aurangabad